

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 6911-0476:153 Page 1 of 1

CATEGORY: Voice Communication System Control Unit

LISTEE: Harrington Signal Inc., 2519 4th Avenue, Moline, IL 61265
Contact: Andrew Keller (309) 762-0731

DESIGN: Models 16MP-HAVE, 32MP-HAVE, 48MP-HAVE, 64MP-HAVE, 80MP-HAVE, 96MP-HAVE, 25DPS-HAVE, 50DPS-HAVE, 100DPS-HAVE, 25DPD-HAVE, 50DPD-HAVE or 100DPD-HAVE audio adjunct/voice evacuation systems. The -MP is the master panel in the system while the -DP is the distributed panel. Each system is modular in construction. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

MPWR-HAVE	Power Supply
MFPC-HAVE	Master Fire Phone Card
CDC-HAVE	Data Communication Control Card
SCA-HAVE	Audio System Control Card
MSSC-HAVE	Switch Scan Card
SCMM-HAVE	Microphone Master Control Card
CIO-HAVE	Input/Output Card
LEDSC-HAVE	Switch and LED Card
FFPM-HAVE	Master Fire Phone Handset Card
RMB-HAVE	Motherboard Card
AMRP-HAVE	Audio Module Interface Card
FIR-HAVE	Fire Phone Interface Card
MBRM-HAVE	Motherboard/Relay Card

RATING: 120 VAC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as voice communication/evacuation/relocation/paging system for use with Evax's Models EVX-25 (CSFM Listing No. 6911-1446:100) or EVX-50 (CSFM Listing No. 6911-1446:102) and separately listed electrically compatible fire alarm control unit.

XLF: 6911-1446:103



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 9, 2002

*Listing Expires **June 30, 2003***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager